

PORTABLE APPLIANCE TESTING (PAT) CERTIFICATE

DETAILS OF CLIENT

Name: Roy Corneloues	Telephone No: 07903 729626
Address: roy@corneloues.co.uk	Post Code:

TEST EQUIPMENT DETAILS

Test equipment used: Seaward PrimeTest 100	Serial No: 31J-0035	Date of Test: 25/02/2022
Tested by: Karl Semmence	No. of pages: 1	Recommended Next Test: 25/02/2023

ID Number	Class or Lead	Location	Description	Result P or F	Risk Comment
1	II	Mobile	Microphone PSU	Pass	M
2	Lead	Mobile	6 way extension lead	Pass	H 13A fuse
3	Lead	Mobile	IEC to Mains	Pass	M 5A rewired plug as earth lead detached
4	I	Mobile	Sound Splitter	Pass	L
5	Lead	Mobile	IEC to Mains	Pass	M 5A changed fuse from 13A
6	I	Mobile	Graphic Equiliser	Pass	L
7	II	Mobile	PSU	Pass	M
8	II	Mobile	KAM microphone TX	Pass	L
9	II	Mobile	KAM microphone TX	Pass	L
10	I	Mobile	Tristar Cloth Controller	Pass	M
11	Lead	Mobile	IEC to Mains	Pass	H 13A fuse
12	Lead	Mobile	IEC to Mains	Pass	H 13A fuse
13	Lead	Mobile	IEC to Mains	Pass	H 3A fuse
14	Lead	Mobile	IEC to Mains	Pass	H 5A fuse
15	Lead	Mobile	IEC to Mains	Pass	H 5A fuse
16	Lead	Mobile	IEC to Mains	Pass	H 13A fuse
17	Lead	Mobile	6 way extension lead	Pass	H 13A tightened screws in plug
18	Lead	Mobile	6 way extension lead	Pass	H 13A fuse
19	Lead	Mobile	4 way extension lead	Pass	H 13A fuse
20	Lead	Mobile	4 way extension lead	Pass	H 13A fuse
21	Lead	Mobile	4 way extension lead	Pass	H 13A tightened screws in plug
22	Lead	Mobile	4 way extension lead	Pass	H 13A fuse
23	Lead	Mobile	JCB 4 way extension lead	Pass	H 13A fuse
24	Lead	Mobile	IEC to Mains	Pass	M 5A changed fuse from 13A
25	II FE	Mobile	PSU	Pass	M
26	III	Mobile	Laptop	Pass	L Visually inspected
27	II	Mobile	PSU	Pass	M
28	II	Mobile	Denon DJ MC700 controller	Pass	L

* All items tested as made available.

* Items tested in line with the current edition of the 'Code of Practice for In-service Inspection and Testing of Electrical Equipment'.